

# Attestation

## BREEAM International

On 1 February 2021, Eurofins Product Testing A/S received a sample of floor coating with the product name:

### 86170 Devo Lignum Pura

supplied by

### Devomat Industries nv


The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 (See test report no. 392-2021-00072101\_F\_EN\_02).

**Evaluation of the emission results according to the exemplary level emission criteria (table 18) of: BREEAM Int.: Hea 02 Indoor air quality:**

- Carcinogenic substances were not detectable after 28 days ( $< 0.001 \text{ mg/m}^3$ )
- The sum of VOC ("TVOC") after 28 days was below the limit of  $0.3 \text{ mg/m}^3$
- The sum of SVOC after 28 day was below the limit of  $0.1 \text{ mg/m}^3$
- Formaldehyde after 28 days was below the limit of  $0.01 \text{ mg/m}^3$

**The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).**

9 July 2021



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry